

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/271/26	Model No.: MARQ-6-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 271/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27001 To 27100 And 27005A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27005A and removed from the Lot/Batch							
27001	Pass	27002	Pass	27003	Pass	27004	Pass
27005	Pass	27006	Pass	27007	Pass	27008	Pass
27009	Pass	27010	Pass	27011	Pass	27012	Pass
27013	Pass	27014	Pass	27015	Pass	27016	Pass
27017	Pass	27018	Pass	27019	Pass	27020	Pass
27021	Pass	27022	Pass	27023	Pass	27024	Pass
27025	Pass	27026	Pass	27027	Pass	27028	Pass
27029	Pass	27030	Pass	27031	Pass	27032	Pass
27033	Pass	27034	Pass	27035	Pass	27036	Pass
27037	Pass	27038	Pass	27039	Pass	27040	Pass
27041	Pass	27042	Pass	27043	Pass	27044	Pass
27045	Pass	27046	Pass	27047	Pass	27048	Pass
27049	Pass	27050	Pass	27051	Pass	27052	Pass
27053	Pass	27054	Pass	27055	Pass	27056	Pass
27057	Pass	27058	Pass	27059	Pass	27060	Pass
27061	Pass	27062	Pass	27063	Pass	27064	Pass
27065	Pass	27066	Pass	27067	Pass	27068	Pass
27069	Pass	27070	Pass	27071	Pass	27072	Pass
27073	Pass	27074	Pass	27075	Pass	27076	Pass
27077	Pass	27078	Pass	27079	Pass	27080	Pass
27081	Pass	27082	Pass	27083	Pass	27084	Pass
27085	Pass	27086	Pass	27087	Pass	27088	Pass
27089	Pass	27090	Pass	27091	Pass	27092	Pass
27093	Pass	27094	Pass	27095	Pass	27096	Pass
27097	Pass	27098	Pass	27099	Pass	27100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory