

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/272/26	Model No.: MARQ-6-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 272/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27101 To 27200 And 27105A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27105A and removed from the Lot/Batch							
27101	Pass	27102	Pass	27103	Pass	27104	Pass
27105	Pass	27106	Pass	27107	Pass	27108	Pass
27109	Pass	27110	Pass	27111	Pass	27112	Pass
27113	Pass	27114	Pass	27115	Pass	27116	Pass
27117	Pass	27118	Pass	27119	Pass	27120	Pass
27121	Pass	27122	Pass	27123	Pass	27124	Pass
27125	Pass	27126	Pass	27127	Pass	27128	Pass
27129	Pass	27130	Pass	27131	Pass	27132	Pass
27133	Pass	27134	Pass	27135	Pass	27136	Pass
27137	Pass	27138	Pass	27139	Pass	27140	Pass
27141	Pass	27142	Pass	27143	Pass	27144	Pass
27145	Pass	27146	Pass	27147	Pass	27148	Pass
27149	Pass	27150	Pass	27151	Pass	27152	Pass
27153	Pass	27154	Pass	27155	Pass	27156	Pass
27157	Pass	27158	Pass	27159	Pass	27160	Pass
27161	Pass	27162	Pass	27163	Pass	27164	Pass
27165	Pass	27166	Pass	27167	Pass	27168	Pass
27169	Pass	27170	Pass	27171	Pass	27172	Pass
27173	Pass	27174	Pass	27175	Pass	27176	Pass
27177	Pass	27178	Pass	27179	Pass	27180	Pass
27181	Pass	27182	Pass	27183	Pass	27184	Pass
27185	Pass	27186	Pass	27187	Pass	27188	Pass
27189	Pass	27190	Pass	27191	Pass	27192	Pass
27193	Pass	27194	Pass	27195	Pass	27196	Pass
27197	Pass	27198	Pass	27199	Pass	27200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory