

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/208/26	Model No.: MARQ-6-40%	Date: 17-07-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 208/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20701 To 20800 And 20705A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20705A and removed from the Lot/Batch							
20701	Pass	20702	Pass	20703	Pass	20704	Pass
20705	Pass	20706	Pass	20707	Pass	20708	Pass
20709	Pass	20710	Pass	20711	Pass	20712	Pass
20713	Pass	20714	Pass	20715	Pass	20716	Pass
20717	Pass	20718	Pass	20719	Pass	20720	Pass
20721	Pass	20722	Pass	20723	Pass	20724	Pass
20725	Pass	20726	Pass	20727	Pass	20728	Pass
20729	Pass	20730	Pass	20731	Pass	20732	Pass
20733	Pass	20734	Pass	20735	Pass	20736	Pass
20737	Pass	20738	Pass	20739	Pass	20740	Pass
20741	Pass	20742	Pass	20743	Pass	20744	Pass
20745	Pass	20746	Pass	20747	Pass	20748	Pass
20749	Pass	20750	Pass	20751	Pass	20752	Pass
20753	Pass	20754	Pass	20755	Pass	20756	Pass
20757	Pass	20758	Pass	20759	Pass	20760	Pass
20761	Pass	20762	Pass	20763	Pass	20764	Pass
20765	Pass	20766	Pass	20767	Pass	20768	Pass
20769	Pass	20770	Pass	20771	Pass	20772	Pass
20773	Pass	20774	Pass	20775	Pass	20776	Pass
20777	Pass	20778	Pass	20779	Pass	20780	Pass
20781	Pass	20782	Pass	20783	Pass	20784	Pass
20785	Pass	20786	Pass	20787	Pass	20788	Pass
20789	Pass	20790	Pass	20791	Pass	20792	Pass
20793	Pass	20794	Pass	20795	Pass	20796	Pass
20797	Pass	20798	Pass	20799	Pass	20800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory