

HYDRO PRESSURE TEST

TC No.: HPT/D75/S/RQ/004/26	Model No.: KFDRQ-75-S	Date: 23-07-2026
Type and Capacity of Extinguisher	: KFDRQ-75-S-Kanex DCP BC Dry Powder (SBC) Fire Extinguisher Cap. 75 Kg.	
Batch Number	: KFDRQ75S 004/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00151 To 200	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (1st batch)							
151	Pass	152	Pass	153	Pass	154	Pass
155	Pass	156	Pass	157	Pass	158	Pass
159	Pass	160	Pass	161	Pass	162	Pass
163	Pass	164	Pass	165	Pass	166	Pass
167	Pass	168	Pass	169	Pass	170	Pass
171	Pass	172	Pass	173	Pass	174	Pass
175	Pass	176	Pass	177	Pass	178	Pass
179	Pass	180	Pass	181	Pass	182	Pass
183	Pass	184	Pass	185	Pass	186	Pass
187	Pass	188	Pass	189	Pass	190	Pass
191	Pass	192	Pass	193	Pass	194	Pass
195	Pass	196	Pass	197	Pass	198	Pass
199	Pass	200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory