

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A50/RQ/216/26      | Model No.: KFARQ-6-50%                                          | Date: 03-07-2026 |
| Type and Capacity of Extinguisher | : KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ50%6 216/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 21501 To 21600 And 21505A                                     |                  |
| Month of Manufacturing            | : Jul/26                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 21505A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 21501                                                         | Pass   | 21502    | Pass   | 21503    | Pass   | 21504    | Pass   |
| 21505                                                         | Pass   | 21506    | Pass   | 21507    | Pass   | 21508    | Pass   |
| 21509                                                         | Pass   | 21510    | Pass   | 21511    | Pass   | 21512    | Pass   |
| 21513                                                         | Pass   | 21514    | Pass   | 21515    | Pass   | 21516    | Pass   |
| 21517                                                         | Pass   | 21518    | Pass   | 21519    | Pass   | 21520    | Pass   |
| 21521                                                         | Pass   | 21522    | Pass   | 21523    | Pass   | 21524    | Pass   |
| 21525                                                         | Pass   | 21526    | Pass   | 21527    | Pass   | 21528    | Pass   |
| 21529                                                         | Pass   | 21530    | Pass   | 21531    | Pass   | 21532    | Pass   |
| 21533                                                         | Pass   | 21534    | Pass   | 21535    | Pass   | 21536    | Pass   |
| 21537                                                         | Pass   | 21538    | Pass   | 21539    | Pass   | 21540    | Pass   |
| 21541                                                         | Pass   | 21542    | Pass   | 21543    | Pass   | 21544    | Pass   |
| 21545                                                         | Pass   | 21546    | Pass   | 21547    | Pass   | 21548    | Pass   |
| 21549                                                         | Pass   | 21550    | Pass   | 21551    | Pass   | 21552    | Pass   |
| 21553                                                         | Pass   | 21554    | Pass   | 21555    | Pass   | 21556    | Pass   |
| 21557                                                         | Pass   | 21558    | Pass   | 21559    | Pass   | 21560    | Pass   |
| 21561                                                         | Pass   | 21562    | Pass   | 21563    | Pass   | 21564    | Pass   |
| 21565                                                         | Pass   | 21566    | Pass   | 21567    | Pass   | 21568    | Pass   |
| 21569                                                         | Pass   | 21570    | Pass   | 21571    | Pass   | 21572    | Pass   |
| 21573                                                         | Pass   | 21574    | Pass   | 21575    | Pass   | 21576    | Pass   |
| 21577                                                         | Pass   | 21578    | Pass   | 21579    | Pass   | 21580    | Pass   |
| 21581                                                         | Pass   | 21582    | Pass   | 21583    | Pass   | 21584    | Pass   |
| 21585                                                         | Pass   | 21586    | Pass   | 21587    | Pass   | 21588    | Pass   |
| 21589                                                         | Pass   | 21590    | Pass   | 21591    | Pass   | 21592    | Pass   |
| 21593                                                         | Pass   | 21594    | Pass   | 21595    | Pass   | 21596    | Pass   |
| 21597                                                         | Pass   | 21598    | Pass   | 21599    | Pass   | 21600    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**