

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/153/26	Model No.: KFARQ-6-90%	Date: 19-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 153/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15201 To 15300 And 15205A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15205A and removed from the Lot/Batch							
15201	Pass	15202	Pass	15203	Pass	15204	Pass
15205	Pass	15206	Pass	15207	Pass	15208	Pass
15209	Pass	15210	Pass	15211	Pass	15212	Pass
15213	Pass	15214	Pass	15215	Pass	15216	Pass
15217	Pass	15218	Pass	15219	Pass	15220	Pass
15221	Pass	15222	Pass	15223	Pass	15224	Pass
15225	Pass	15226	Pass	15227	Pass	15228	Pass
15229	Pass	15230	Pass	15231	Pass	15232	Pass
15233	Pass	15234	Pass	15235	Pass	15236	Pass
15237	Pass	15238	Pass	15239	Pass	15240	Pass
15241	Pass	15242	Pass	15243	Pass	15244	Pass
15245	Pass	15246	Pass	15247	Pass	15248	Pass
15249	Pass	15250	Pass	15251	Pass	15252	Pass
15253	Pass	15254	Pass	15255	Pass	15256	Pass
15257	Pass	15258	Pass	15259	Pass	15260	Pass
15261	Pass	15262	Pass	15263	Pass	15264	Pass
15265	Pass	15266	Pass	15267	Pass	15268	Pass
15269	Pass	15270	Pass	15271	Pass	15272	Pass
15273	Pass	15274	Pass	15275	Pass	15276	Pass
15277	Pass	15278	Pass	15279	Pass	15280	Pass
15281	Pass	15282	Pass	15283	Pass	15284	Pass
15285	Pass	15286	Pass	15287	Pass	15288	Pass
15289	Pass	15290	Pass	15291	Pass	15292	Pass
15293	Pass	15294	Pass	15295	Pass	15296	Pass
15297	Pass	15298	Pass	15299	Pass	15300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory