

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/046/26	Model No.: KMCRQ-5	Date: 21-06-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 046/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02251 To 2300	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 02251 To 2300 and removed from the Lot/Batch							
2251	Pass	2252	Pass	2253	Pass	2254	Pass
2255	Pass	2256	Pass	2257	Pass	2258	Pass
2259	Pass	2260	Pass	2261	Pass	2262	Pass
2263	Pass	2264	Pass	2265	Pass	2266	Pass
2267	Pass	2268	Pass	2269	Pass	2270	Pass
2271	Pass	2272	Pass	2273	Pass	2274	Pass
2275	Pass	2276	Pass	2277	Pass	2278	Pass
2279	Pass	2280	Pass	2281	Pass	2282	Pass
2283	Pass	2284	Pass	2285	Pass	2286	Pass
2287	Pass	2288	Pass	2289	Pass	2290	Pass
2291	Pass	2292	Pass	2293	Pass	2294	Pass
2295	Pass	2296	Pass	2297	Pass	2298	Pass
2299	Pass	2300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory