

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ9/009/26

Model No.: KFLIHQ-9

Date: 28-04-2026

Type and Capacity of Extinguisher : KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr.

Batch Number : KFLIHQ9 009/26

Batch Quantity : 10 Nos.

Serial Numbers : 00081 To 90

Month of Manufacturing : Apr/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
81	Pass	82	Pass	83	Pass	84	Pass
85	Pass	86	Pass	87	Pass	88	Pass
89	Pass	90	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**