KANEX
Kanex Fire Solutions Limited

HYDRO PRESSURE TEST

TC No.: HPT/MA2/A40/RQ/011/26	Model No.: MARQ-2-40%	Date: 02-06-2026

Type and Capacity of Extinguisher	: MARQ-2-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.
Batch Number	: MARQ40%2 011/26
Batch Quantity	: 101.00 Nos.
Serial Numbers	: 01001 To 1100 And 1005A
Month of Manufacturing	: Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1005A and removed from the Lot/Batch							
1001	Pass	1002	Pass	1003	Pass	1004	Pass
1005	Pass	1006	Pass	1007	Pass	1008	Pass
1009	Pass	1010	Pass	1011	Pass	1012	Pass
1013	Pass	1014	Pass	1015	Pass	1016	Pass
1017	Pass	1018	Pass	1019	Pass	1020	Pass
1021	Pass	1022	Pass	1023	Pass	1024	Pass
1025	Pass	1026	Pass	1027	Pass	1028	Pass
1029	Pass	1030	Pass	1031	Pass	1032	Pass
1033	Pass	1034	Pass	1035	Pass	1036	Pass
1037	Pass	1038	Pass	1039	Pass	1040	Pass
1041	Pass	1042	Pass	1043	Pass	1044	Pass
1045	Pass	1046	Pass	1047	Pass	1048	Pass
1049	Pass	1050	Pass	1051	Pass	1052	Pass
1053	Pass	1054	Pass	1055	Pass	1056	Pass
1057	Pass	1058	Pass	1059	Pass	1060	Pass
1061	Pass	1062	Pass	1063	Pass	1064	Pass
1065	Pass	1066	Pass	1067	Pass	1068	Pass
1069	Pass	1070	Pass	1071	Pass	1072	Pass
1073	Pass	1074	Pass	1075	Pass	1076	Pass
1077	Pass	1078	Pass	1079	Pass	1080	Pass
1081	Pass	1082	Pass	1083	Pass	1084	Pass
1085	Pass	1086	Pass	1087	Pass	1088	Pass
1089	Pass	1090	Pass	1091	Pass	1092	Pass
1093	Pass	1094	Pass	1095	Pass	1096	Pass
1097	Pass	1098	Pass	1099	Pass	1100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

KANEX FIRE SOLUTIONS LIMITED SIHOR (GUJARAT)

Authorized Signatory