

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/222/26	Model No.: KFARQ-6-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 222/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22101 To 22200 And 22105A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22105A and removed from the Lot/Batch							
22101	Pass	22102	Pass	22103	Pass	22104	Pass
22105	Pass	22106	Pass	22107	Pass	22108	Pass
22109	Pass	22110	Pass	22111	Pass	22112	Pass
22113	Pass	22114	Pass	22115	Pass	22116	Pass
22117	Pass	22118	Pass	22119	Pass	22120	Pass
22121	Pass	22122	Pass	22123	Pass	22124	Pass
22125	Pass	22126	Pass	22127	Pass	22128	Pass
22129	Pass	22130	Pass	22131	Pass	22132	Pass
22133	Pass	22134	Pass	22135	Pass	22136	Pass
22137	Pass	22138	Pass	22139	Pass	22140	Pass
22141	Pass	22142	Pass	22143	Pass	22144	Pass
22145	Pass	22146	Pass	22147	Pass	22148	Pass
22149	Pass	22150	Pass	22151	Pass	22152	Pass
22153	Pass	22154	Pass	22155	Pass	22156	Pass
22157	Pass	22158	Pass	22159	Pass	22160	Pass
22161	Pass	22162	Pass	22163	Pass	22164	Pass
22165	Pass	22166	Pass	22167	Pass	22168	Pass
22169	Pass	22170	Pass	22171	Pass	22172	Pass
22173	Pass	22174	Pass	22175	Pass	22176	Pass
22177	Pass	22178	Pass	22179	Pass	22180	Pass
22181	Pass	22182	Pass	22183	Pass	22184	Pass
22185	Pass	22186	Pass	22187	Pass	22188	Pass
22189	Pass	22190	Pass	22191	Pass	22192	Pass
22193	Pass	22194	Pass	22195	Pass	22196	Pass
22197	Pass	22198	Pass	22199	Pass	22200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory