

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/273/26	Model No.: MARQ-6-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 273/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27201 To 27300 And 27205A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27205A and removed from the Lot/Batch							
27201	Pass	27202	Pass	27203	Pass	27204	Pass
27205	Pass	27206	Pass	27207	Pass	27208	Pass
27209	Pass	27210	Pass	27211	Pass	27212	Pass
27213	Pass	27214	Pass	27215	Pass	27216	Pass
27217	Pass	27218	Pass	27219	Pass	27220	Pass
27221	Pass	27222	Pass	27223	Pass	27224	Pass
27225	Pass	27226	Pass	27227	Pass	27228	Pass
27229	Pass	27230	Pass	27231	Pass	27232	Pass
27233	Pass	27234	Pass	27235	Pass	27236	Pass
27237	Pass	27238	Pass	27239	Pass	27240	Pass
27241	Pass	27242	Pass	27243	Pass	27244	Pass
27245	Pass	27246	Pass	27247	Pass	27248	Pass
27249	Pass	27250	Pass	27251	Pass	27252	Pass
27253	Pass	27254	Pass	27255	Pass	27256	Pass
27257	Pass	27258	Pass	27259	Pass	27260	Pass
27261	Pass	27262	Pass	27263	Pass	27264	Pass
27265	Pass	27266	Pass	27267	Pass	27268	Pass
27269	Pass	27270	Pass	27271	Pass	27272	Pass
27273	Pass	27274	Pass	27275	Pass	27276	Pass
27277	Pass	27278	Pass	27279	Pass	27280	Pass
27281	Pass	27282	Pass	27283	Pass	27284	Pass
27285	Pass	27286	Pass	27287	Pass	27288	Pass
27289	Pass	27290	Pass	27291	Pass	27292	Pass
27293	Pass	27294	Pass	27295	Pass	27296	Pass
27297	Pass	27298	Pass	27299	Pass	27300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory