

HYDRO PRESSURE TEST

TC No.: HPT/A2/A50/SS/HQ/005/26	Model No.: KFASSHQ-2-50%	Date: 25-07-2026
Type and Capacity of Extinguisher	: KFASSHQ-2-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFASSHQ50%2 005/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00041 To 50 And 45A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 45A and removed from the Lot/Batch							
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory