



# Warranty Certificate

Date: 30-07-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Clean Fino-Chem Limited**Warranty Start Date:** 30-07-2026**Warranty End Date:** 29-07-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                                 | Quantity | Sr. Nos.            |
|--------|------------------------------------------------------------------|----------|---------------------|
| 1      | KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg. | 7        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/003901 Dated: 30-07-2026 P.O.No. PO/10985** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**