

HYDRO PRESSURE TEST

TC No.: HPT/CA2/SS/RQ/007/26	Model No.: KCASSRQ-2	Date: 25-07-2026
Type and Capacity of Extinguisher	: KCASSRQ-2-Kanex SS Clean Agent Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KCASSRQ2 007/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00061 To 70 And 65A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 65A and removed from the Lot/Batch							
61	Pass	62	Pass	63	Pass	64	Pass
65	Pass	66	Pass	67	Pass	68	Pass
69	Pass	70	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory