

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/189/26	Model No.: KFARQ-6-90%	Date: 17-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 189/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18801 To 18900 And 18805A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18805A and removed from the Lot/Batch							
18801	Pass	18802	Pass	18803	Pass	18804	Pass
18805	Pass	18806	Pass	18807	Pass	18808	Pass
18809	Pass	18810	Pass	18811	Pass	18812	Pass
18813	Pass	18814	Pass	18815	Pass	18816	Pass
18817	Pass	18818	Pass	18819	Pass	18820	Pass
18821	Pass	18822	Pass	18823	Pass	18824	Pass
18825	Pass	18826	Pass	18827	Pass	18828	Pass
18829	Pass	18830	Pass	18831	Pass	18832	Pass
18833	Pass	18834	Pass	18835	Pass	18836	Pass
18837	Pass	18838	Pass	18839	Pass	18840	Pass
18841	Pass	18842	Pass	18843	Pass	18844	Pass
18845	Pass	18846	Pass	18847	Pass	18848	Pass
18849	Pass	18850	Pass	18851	Pass	18852	Pass
18853	Pass	18854	Pass	18855	Pass	18856	Pass
18857	Pass	18858	Pass	18859	Pass	18860	Pass
18861	Pass	18862	Pass	18863	Pass	18864	Pass
18865	Pass	18866	Pass	18867	Pass	18868	Pass
18869	Pass	18870	Pass	18871	Pass	18872	Pass
18873	Pass	18874	Pass	18875	Pass	18876	Pass
18877	Pass	18878	Pass	18879	Pass	18880	Pass
18881	Pass	18882	Pass	18883	Pass	18884	Pass
18885	Pass	18886	Pass	18887	Pass	18888	Pass
18889	Pass	18890	Pass	18891	Pass	18892	Pass
18893	Pass	18894	Pass	18895	Pass	18896	Pass
18897	Pass	18898	Pass	18899	Pass	18900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory