

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/098/26	Model No.: KMCRQ-10	Date: 11-07-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 098/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00971 To 980	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00971 To 980 and removed from the Lot/Batch							
971	Pass	972	Pass	973	Pass	974	Pass
975	Pass	976	Pass	977	Pass	978	Pass
979	Pass	980	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory