

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/101/26	Model No.: KMCRQ-10	Date: 11-07-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 101/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01001 To 1010	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01001 To 1010 and removed from the Lot/Batch							
1001	Pass	1002	Pass	1003	Pass	1004	Pass
1005	Pass	1006	Pass	1007	Pass	1008	Pass
1009	Pass	1010	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory