

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/055/26	Model No.: MARQ-4-50%	Date: 26-06-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 055/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05401 To 5500 And 5405A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5405A and removed from the Lot/Batch							
5401	Pass	5402	Pass	5403	Pass	5404	Pass
5405	Pass	5406	Pass	5407	Pass	5408	Pass
5409	Pass	5410	Pass	5411	Pass	5412	Pass
5413	Pass	5414	Pass	5415	Pass	5416	Pass
5417	Pass	5418	Pass	5419	Pass	5420	Pass
5421	Pass	5422	Pass	5423	Pass	5424	Pass
5425	Pass	5426	Pass	5427	Pass	5428	Pass
5429	Pass	5430	Pass	5431	Pass	5432	Pass
5433	Pass	5434	Pass	5435	Pass	5436	Pass
5437	Pass	5438	Pass	5439	Pass	5440	Pass
5441	Pass	5442	Pass	5443	Pass	5444	Pass
5445	Pass	5446	Pass	5447	Pass	5448	Pass
5449	Pass	5450	Pass	5451	Pass	5452	Pass
5453	Pass	5454	Pass	5455	Pass	5456	Pass
5457	Pass	5458	Pass	5459	Pass	5460	Pass
5461	Pass	5462	Pass	5463	Pass	5464	Pass
5465	Pass	5466	Pass	5467	Pass	5468	Pass
5469	Pass	5470	Pass	5471	Pass	5472	Pass
5473	Pass	5474	Pass	5475	Pass	5476	Pass
5477	Pass	5478	Pass	5479	Pass	5480	Pass
5481	Pass	5482	Pass	5483	Pass	5484	Pass
5485	Pass	5486	Pass	5487	Pass	5488	Pass
5489	Pass	5490	Pass	5491	Pass	5492	Pass
5493	Pass	5494	Pass	5495	Pass	5496	Pass
5497	Pass	5498	Pass	5499	Pass	5500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory