

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A50/RQ/056/26     | Model No.: MARQ-4-50%                                          | Date: 03-07-2026 |
| Type and Capacity of Extinguisher | : MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ50%4 056/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 05501 To 5600 And 5505A                                      |                  |
| Month of Manufacturing            | : Jul/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 5505A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 5501                                                         | Pass   | 5502     | Pass   | 5503     | Pass   | 5504     | Pass   |
| 5505                                                         | Pass   | 5506     | Pass   | 5507     | Pass   | 5508     | Pass   |
| 5509                                                         | Pass   | 5510     | Pass   | 5511     | Pass   | 5512     | Pass   |
| 5513                                                         | Pass   | 5514     | Pass   | 5515     | Pass   | 5516     | Pass   |
| 5517                                                         | Pass   | 5518     | Pass   | 5519     | Pass   | 5520     | Pass   |
| 5521                                                         | Pass   | 5522     | Pass   | 5523     | Pass   | 5524     | Pass   |
| 5525                                                         | Pass   | 5526     | Pass   | 5527     | Pass   | 5528     | Pass   |
| 5529                                                         | Pass   | 5530     | Pass   | 5531     | Pass   | 5532     | Pass   |
| 5533                                                         | Pass   | 5534     | Pass   | 5535     | Pass   | 5536     | Pass   |
| 5537                                                         | Pass   | 5538     | Pass   | 5539     | Pass   | 5540     | Pass   |
| 5541                                                         | Pass   | 5542     | Pass   | 5543     | Pass   | 5544     | Pass   |
| 5545                                                         | Pass   | 5546     | Pass   | 5547     | Pass   | 5548     | Pass   |
| 5549                                                         | Pass   | 5550     | Pass   | 5551     | Pass   | 5552     | Pass   |
| 5553                                                         | Pass   | 5554     | Pass   | 5555     | Pass   | 5556     | Pass   |
| 5557                                                         | Pass   | 5558     | Pass   | 5559     | Pass   | 5560     | Pass   |
| 5561                                                         | Pass   | 5562     | Pass   | 5563     | Pass   | 5564     | Pass   |
| 5565                                                         | Pass   | 5566     | Pass   | 5567     | Pass   | 5568     | Pass   |
| 5569                                                         | Pass   | 5570     | Pass   | 5571     | Pass   | 5572     | Pass   |
| 5573                                                         | Pass   | 5574     | Pass   | 5575     | Pass   | 5576     | Pass   |
| 5577                                                         | Pass   | 5578     | Pass   | 5579     | Pass   | 5580     | Pass   |
| 5581                                                         | Pass   | 5582     | Pass   | 5583     | Pass   | 5584     | Pass   |
| 5585                                                         | Pass   | 5586     | Pass   | 5587     | Pass   | 5588     | Pass   |
| 5589                                                         | Pass   | 5590     | Pass   | 5591     | Pass   | 5592     | Pass   |
| 5593                                                         | Pass   | 5594     | Pass   | 5595     | Pass   | 5596     | Pass   |
| 5597                                                         | Pass   | 5598     | Pass   | 5599     | Pass   | 5600     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**