

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/096/26	Model No.: KMCRQ-10	Date: 10-07-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 096/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00951 To 960	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00951 To 960 and removed from the Lot/Batch							
951	Pass	952	Pass	953	Pass	954	Pass
955	Pass	956	Pass	957	Pass	958	Pass
959	Pass	960	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory