

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/043/26	Model No.: KFMSRQ-9	Date: 06-07-2026
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 043/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04201 To 4300 And 4205A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4205A and removed from the Lot/Batch							
4201	Pass	4202	Pass	4203	Pass	4204	Pass
4205	Pass	4206	Pass	4207	Pass	4208	Pass
4209	Pass	4210	Pass	4211	Pass	4212	Pass
4213	Pass	4214	Pass	4215	Pass	4216	Pass
4217	Pass	4218	Pass	4219	Pass	4220	Pass
4221	Pass	4222	Pass	4223	Pass	4224	Pass
4225	Pass	4226	Pass	4227	Pass	4228	Pass
4229	Pass	4230	Pass	4231	Pass	4232	Pass
4233	Pass	4234	Pass	4235	Pass	4236	Pass
4237	Pass	4238	Pass	4239	Pass	4240	Pass
4241	Pass	4242	Pass	4243	Pass	4244	Pass
4245	Pass	4246	Pass	4247	Pass	4248	Pass
4249	Pass	4250	Pass	4251	Pass	4252	Pass
4253	Pass	4254	Pass	4255	Pass	4256	Pass
4257	Pass	4258	Pass	4259	Pass	4260	Pass
4261	Pass	4262	Pass	4263	Pass	4264	Pass
4265	Pass	4266	Pass	4267	Pass	4268	Pass
4269	Pass	4270	Pass	4271	Pass	4272	Pass
4273	Pass	4274	Pass	4275	Pass	4276	Pass
4277	Pass	4278	Pass	4279	Pass	4280	Pass
4281	Pass	4282	Pass	4283	Pass	4284	Pass
4285	Pass	4286	Pass	4287	Pass	4288	Pass
4289	Pass	4290	Pass	4291	Pass	4292	Pass
4293	Pass	4294	Pass	4295	Pass	4296	Pass
4297	Pass	4298	Pass	4299	Pass	4300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory