

HYDRO PRESSURE TEST

TC No.: HPT/KF/LI/KV/RQ4/001/26	Model No.: KFLIKVRQ-4	Date: 26-07-2026
Type and Capacity of Extinguisher	: KV-LITE K-900 (Multipurpose Encapsulating Agent) Stored Pressure Fire Extinguisher	
Batch Number	: KFLIKVRQ4 001/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00001 To 10 And 5A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5A and removed from the Lot/Batch							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory