

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/061/26	Model No.: MARQ-4-50%	Date: 20-07-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 061/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06001 To 6100 And 6005A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6005A and removed from the Lot/Batch							
6001	Pass	6002	Pass	6003	Pass	6004	Pass
6005	Pass	6006	Pass	6007	Pass	6008	Pass
6009	Pass	6010	Pass	6011	Pass	6012	Pass
6013	Pass	6014	Pass	6015	Pass	6016	Pass
6017	Pass	6018	Pass	6019	Pass	6020	Pass
6021	Pass	6022	Pass	6023	Pass	6024	Pass
6025	Pass	6026	Pass	6027	Pass	6028	Pass
6029	Pass	6030	Pass	6031	Pass	6032	Pass
6033	Pass	6034	Pass	6035	Pass	6036	Pass
6037	Pass	6038	Pass	6039	Pass	6040	Pass
6041	Pass	6042	Pass	6043	Pass	6044	Pass
6045	Pass	6046	Pass	6047	Pass	6048	Pass
6049	Pass	6050	Pass	6051	Pass	6052	Pass
6053	Pass	6054	Pass	6055	Pass	6056	Pass
6057	Pass	6058	Pass	6059	Pass	6060	Pass
6061	Pass	6062	Pass	6063	Pass	6064	Pass
6065	Pass	6066	Pass	6067	Pass	6068	Pass
6069	Pass	6070	Pass	6071	Pass	6072	Pass
6073	Pass	6074	Pass	6075	Pass	6076	Pass
6077	Pass	6078	Pass	6079	Pass	6080	Pass
6081	Pass	6082	Pass	6083	Pass	6084	Pass
6085	Pass	6086	Pass	6087	Pass	6088	Pass
6089	Pass	6090	Pass	6091	Pass	6092	Pass
6093	Pass	6094	Pass	6095	Pass	6096	Pass
6097	Pass	6098	Pass	6099	Pass	6100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory