

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/024/26

Model No.: KFKHQ-9

Date: 17-06-2026

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 024/26

Batch Quantity : 10 Nos.

Serial Numbers : 00231 To 240

Month of Manufacturing : Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
231	Pass	232	Pass	233	Pass	234	Pass
235	Pass	236	Pass	237	Pass	238	Pass
239	Pass	240	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**