

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/026/26	Model No.: KFKHQ-9	Date: 27-06-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 026/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00251 To 260	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
251	Pass	252	Pass	253	Pass	254	Pass
255	Pass	256	Pass	257	Pass	258	Pass
259	Pass	260	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory