

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/197/26	Model No.: KFARQ-6-90%	Date: 25-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 197/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19601 To 19700 And 19605A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19605A and removed from the Lot/Batch							
19601	Pass	19602	Pass	19603	Pass	19604	Pass
19605	Pass	19606	Pass	19607	Pass	19608	Pass
19609	Pass	19610	Pass	19611	Pass	19612	Pass
19613	Pass	19614	Pass	19615	Pass	19616	Pass
19617	Pass	19618	Pass	19619	Pass	19620	Pass
19621	Pass	19622	Pass	19623	Pass	19624	Pass
19625	Pass	19626	Pass	19627	Pass	19628	Pass
19629	Pass	19630	Pass	19631	Pass	19632	Pass
19633	Pass	19634	Pass	19635	Pass	19636	Pass
19637	Pass	19638	Pass	19639	Pass	19640	Pass
19641	Pass	19642	Pass	19643	Pass	19644	Pass
19645	Pass	19646	Pass	19647	Pass	19648	Pass
19649	Pass	19650	Pass	19651	Pass	19652	Pass
19653	Pass	19654	Pass	19655	Pass	19656	Pass
19657	Pass	19658	Pass	19659	Pass	19660	Pass
19661	Pass	19662	Pass	19663	Pass	19664	Pass
19665	Pass	19666	Pass	19667	Pass	19668	Pass
19669	Pass	19670	Pass	19671	Pass	19672	Pass
19673	Pass	19674	Pass	19675	Pass	19676	Pass
19677	Pass	19678	Pass	19679	Pass	19680	Pass
19681	Pass	19682	Pass	19683	Pass	19684	Pass
19685	Pass	19686	Pass	19687	Pass	19688	Pass
19689	Pass	19690	Pass	19691	Pass	19692	Pass
19693	Pass	19694	Pass	19695	Pass	19696	Pass
19697	Pass	19698	Pass	19699	Pass	19700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory