

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/093/26	Model No.: KFARQ-4-90%	Date: 14-04-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 093/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09201 To 9300 And 9205A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9205A and removed from the Lot/Batch							
9201	Pass	9202	Pass	9203	Pass	9204	Pass
9205	Pass	9206	Pass	9207	Pass	9208	Pass
9209	Pass	9210	Pass	9211	Pass	9212	Pass
9213	Pass	9214	Pass	9215	Pass	9216	Pass
9217	Pass	9218	Pass	9219	Pass	9220	Pass
9221	Pass	9222	Pass	9223	Pass	9224	Pass
9225	Pass	9226	Pass	9227	Pass	9228	Pass
9229	Pass	9230	Pass	9231	Pass	9232	Pass
9233	Pass	9234	Pass	9235	Pass	9236	Pass
9237	Pass	9238	Pass	9239	Pass	9240	Pass
9241	Pass	9242	Pass	9243	Pass	9244	Pass
9245	Pass	9246	Pass	9247	Pass	9248	Pass
9249	Pass	9250	Pass	9251	Pass	9252	Pass
9253	Pass	9254	Pass	9255	Pass	9256	Pass
9257	Pass	9258	Pass	9259	Pass	9260	Pass
9261	Pass	9262	Pass	9263	Pass	9264	Pass
9265	Pass	9266	Pass	9267	Pass	9268	Pass
9269	Pass	9270	Pass	9271	Pass	9272	Pass
9273	Pass	9274	Pass	9275	Pass	9276	Pass
9277	Pass	9278	Pass	9279	Pass	9280	Pass
9281	Pass	9282	Pass	9283	Pass	9284	Pass
9285	Pass	9286	Pass	9287	Pass	9288	Pass
9289	Pass	9290	Pass	9291	Pass	9292	Pass
9293	Pass	9294	Pass	9295	Pass	9296	Pass
9297	Pass	9298	Pass	9299	Pass	9300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory