

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/063/26	Model No.: MARQ-4-50%	Date: 26-07-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 063/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06201 To 6300 And 6205A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6205A and removed from the Lot/Batch							
6201	Pass	6202	Pass	6203	Pass	6204	Pass
6205	Pass	6206	Pass	6207	Pass	6208	Pass
6209	Pass	6210	Pass	6211	Pass	6212	Pass
6213	Pass	6214	Pass	6215	Pass	6216	Pass
6217	Pass	6218	Pass	6219	Pass	6220	Pass
6221	Pass	6222	Pass	6223	Pass	6224	Pass
6225	Pass	6226	Pass	6227	Pass	6228	Pass
6229	Pass	6230	Pass	6231	Pass	6232	Pass
6233	Pass	6234	Pass	6235	Pass	6236	Pass
6237	Pass	6238	Pass	6239	Pass	6240	Pass
6241	Pass	6242	Pass	6243	Pass	6244	Pass
6245	Pass	6246	Pass	6247	Pass	6248	Pass
6249	Pass	6250	Pass	6251	Pass	6252	Pass
6253	Pass	6254	Pass	6255	Pass	6256	Pass
6257	Pass	6258	Pass	6259	Pass	6260	Pass
6261	Pass	6262	Pass	6263	Pass	6264	Pass
6265	Pass	6266	Pass	6267	Pass	6268	Pass
6269	Pass	6270	Pass	6271	Pass	6272	Pass
6273	Pass	6274	Pass	6275	Pass	6276	Pass
6277	Pass	6278	Pass	6279	Pass	6280	Pass
6281	Pass	6282	Pass	6283	Pass	6284	Pass
6285	Pass	6286	Pass	6287	Pass	6288	Pass
6289	Pass	6290	Pass	6291	Pass	6292	Pass
6293	Pass	6294	Pass	6295	Pass	6296	Pass
6297	Pass	6298	Pass	6299	Pass	6300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory