

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/036/26	Model No.: KFMRQ-45	Date: 21-07-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 036/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01751 To 1800	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1505A and which is removed from the batch (31st batch)							
1751	Pass	1752	Pass	1753	Pass	1754	Pass
1755	Pass	1756	Pass	1757	Pass	1758	Pass
1759	Pass	1760	Pass	1761	Pass	1762	Pass
1763	Pass	1764	Pass	1765	Pass	1766	Pass
1767	Pass	1768	Pass	1769	Pass	1770	Pass
1771	Pass	1772	Pass	1773	Pass	1774	Pass
1775	Pass	1776	Pass	1777	Pass	1778	Pass
1779	Pass	1780	Pass	1781	Pass	1782	Pass
1783	Pass	1784	Pass	1785	Pass	1786	Pass
1787	Pass	1788	Pass	1789	Pass	1790	Pass
1791	Pass	1792	Pass	1793	Pass	1794	Pass
1795	Pass	1796	Pass	1797	Pass	1798	Pass
1799	Pass	1800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory