

**HELIUM LEAK DETECTION TEST**

TC No.: HLD/A6/K/HQ/098/26

Model No.: KFKHQ-6

Date: 05-07-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 098/26

Batch Quantity : 10 Nos.

Serial Numbers : 00971 To 980

Month of Manufacturing : Jul/26

| Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------|--------|----------|--------|----------|--------|----------|--------|
| 971      | Pass   | 972      | Pass   | 973      | Pass   | 974      | Pass   |
| 975      | Pass   | 976      | Pass   | 977      | Pass   | 978      | Pass   |
| 979      | Pass   | 980      | Pass   |          |        |          |        |

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of  $1 \times 10^{-6}$  mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**