

# HYDRO PRESSURE TEST

|                                   |                                                          |                  |
|-----------------------------------|----------------------------------------------------------|------------------|
| TC No.: HPT/F9/SP/RQ/042/26       | Model No.: KFMSRQ-9                                      | Date: 23-06-2026 |
| Type and Capacity of Extinguisher | : KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFMSRQ9 042/26                                         |                  |
| Batch Quantity                    | : 101.00 Nos.                                            |                  |
| Serial Numbers                    | : 04101 To 4200 And 4105A                                |                  |
| Month of Manufacturing            | : Jun/26                                                 |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 4105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 4101                                                         | Pass   | 4102     | Pass   | 4103     | Pass   | 4104     | Pass   |
| 4105                                                         | Pass   | 4106     | Pass   | 4107     | Pass   | 4108     | Pass   |
| 4109                                                         | Pass   | 4110     | Pass   | 4111     | Pass   | 4112     | Pass   |
| 4113                                                         | Pass   | 4114     | Pass   | 4115     | Pass   | 4116     | Pass   |
| 4117                                                         | Pass   | 4118     | Pass   | 4119     | Pass   | 4120     | Pass   |
| 4121                                                         | Pass   | 4122     | Pass   | 4123     | Pass   | 4124     | Pass   |
| 4125                                                         | Pass   | 4126     | Pass   | 4127     | Pass   | 4128     | Pass   |
| 4129                                                         | Pass   | 4130     | Pass   | 4131     | Pass   | 4132     | Pass   |
| 4133                                                         | Pass   | 4134     | Pass   | 4135     | Pass   | 4136     | Pass   |
| 4137                                                         | Pass   | 4138     | Pass   | 4139     | Pass   | 4140     | Pass   |
| 4141                                                         | Pass   | 4142     | Pass   | 4143     | Pass   | 4144     | Pass   |
| 4145                                                         | Pass   | 4146     | Pass   | 4147     | Pass   | 4148     | Pass   |
| 4149                                                         | Pass   | 4150     | Pass   | 4151     | Pass   | 4152     | Pass   |
| 4153                                                         | Pass   | 4154     | Pass   | 4155     | Pass   | 4156     | Pass   |
| 4157                                                         | Pass   | 4158     | Pass   | 4159     | Pass   | 4160     | Pass   |
| 4161                                                         | Pass   | 4162     | Pass   | 4163     | Pass   | 4164     | Pass   |
| 4165                                                         | Pass   | 4166     | Pass   | 4167     | Pass   | 4168     | Pass   |
| 4169                                                         | Pass   | 4170     | Pass   | 4171     | Pass   | 4172     | Pass   |
| 4173                                                         | Pass   | 4174     | Pass   | 4175     | Pass   | 4176     | Pass   |
| 4177                                                         | Pass   | 4178     | Pass   | 4179     | Pass   | 4180     | Pass   |
| 4181                                                         | Pass   | 4182     | Pass   | 4183     | Pass   | 4184     | Pass   |
| 4185                                                         | Pass   | 4186     | Pass   | 4187     | Pass   | 4188     | Pass   |
| 4189                                                         | Pass   | 4190     | Pass   | 4191     | Pass   | 4192     | Pass   |
| 4193                                                         | Pass   | 4194     | Pass   | 4195     | Pass   | 4196     | Pass   |
| 4197                                                         | Pass   | 4198     | Pass   | 4199     | Pass   | 4200     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**