

HYDRO PRESSURE TEST

TC No.: HPT/WM9/HQ/016/26	Model No.: KFWMSHQ-9	Date: 17-02-2026
Type and Capacity of Extinguisher	: KFWMSHQ-9-Water Mist Type Portable Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFWMSHQ9 016/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00151 To 160 And 155A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 155A and removed from the Lot/Batch							
151	Pass	152	Pass	153	Pass	154	Pass
155	Pass	156	Pass	157	Pass	158	Pass
159	Pass	160	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**