

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/237/26	Model No.: KFARQ-6-50%	Date: 21-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 237/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23601 To 23700 And 23605A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23605A and removed from the Lot/Batch							
23601	Pass	23602	Pass	23603	Pass	23604	Pass
23605	Pass	23606	Pass	23607	Pass	23608	Pass
23609	Pass	23610	Pass	23611	Pass	23612	Pass
23613	Pass	23614	Pass	23615	Pass	23616	Pass
23617	Pass	23618	Pass	23619	Pass	23620	Pass
23621	Pass	23622	Pass	23623	Pass	23624	Pass
23625	Pass	23626	Pass	23627	Pass	23628	Pass
23629	Pass	23630	Pass	23631	Pass	23632	Pass
23633	Pass	23634	Pass	23635	Pass	23636	Pass
23637	Pass	23638	Pass	23639	Pass	23640	Pass
23641	Pass	23642	Pass	23643	Pass	23644	Pass
23645	Pass	23646	Pass	23647	Pass	23648	Pass
23649	Pass	23650	Pass	23651	Pass	23652	Pass
23653	Pass	23654	Pass	23655	Pass	23656	Pass
23657	Pass	23658	Pass	23659	Pass	23660	Pass
23661	Pass	23662	Pass	23663	Pass	23664	Pass
23665	Pass	23666	Pass	23667	Pass	23668	Pass
23669	Pass	23670	Pass	23671	Pass	23672	Pass
23673	Pass	23674	Pass	23675	Pass	23676	Pass
23677	Pass	23678	Pass	23679	Pass	23680	Pass
23681	Pass	23682	Pass	23683	Pass	23684	Pass
23685	Pass	23686	Pass	23687	Pass	23688	Pass
23689	Pass	23690	Pass	23691	Pass	23692	Pass
23693	Pass	23694	Pass	23695	Pass	23696	Pass
23697	Pass	23698	Pass	23699	Pass	23700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory