

HYDRO PRESSURE TEST

TC No.: HPT/A6/M/RQ/010/25	Model No.: KFDMSRQ-6	Date: 14-08-2025
Type and Capacity of Extinguisher	: KFDMSRQ-6-Kanex D Type Metal SP Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFDMSRQ6 010/25	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00181 To 200 And 185A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 185A and removed from the Lot/Batch							
181	Pass	182	Pass	183	Pass	184	Pass
185	Pass	186	Pass	187	Pass	188	Pass
189	Pass	190	Pass	191	Pass	192	Pass
193	Pass	194	Pass	195	Pass	196	Pass
197	Pass	198	Pass	199	Pass	200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory