

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/037/26	Model No.: KFMRQ-45	Date: 27-07-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 037/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01801 To 1850	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1505A and which is removed from the batch (31st batch)							
1801	Pass	1802	Pass	1803	Pass	1804	Pass
1805	Pass	1806	Pass	1807	Pass	1808	Pass
1809	Pass	1810	Pass	1811	Pass	1812	Pass
1813	Pass	1814	Pass	1815	Pass	1816	Pass
1817	Pass	1818	Pass	1819	Pass	1820	Pass
1821	Pass	1822	Pass	1823	Pass	1824	Pass
1825	Pass	1826	Pass	1827	Pass	1828	Pass
1829	Pass	1830	Pass	1831	Pass	1832	Pass
1833	Pass	1834	Pass	1835	Pass	1836	Pass
1837	Pass	1838	Pass	1839	Pass	1840	Pass
1841	Pass	1842	Pass	1843	Pass	1844	Pass
1845	Pass	1846	Pass	1847	Pass	1848	Pass
1849	Pass	1850	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory