

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/106/26	Model No.: KMCRQ-10	Date: 26-07-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 106/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01051 To 1060	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01051 To 1060 and removed from the Lot/Batch							
1051	Pass	1052	Pass	1053	Pass	1054	Pass
1055	Pass	1056	Pass	1057	Pass	1058	Pass
1059	Pass	1060	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory