

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A50/RQ/062/26     | Model No.: MARQ-4-50%                                          | Date: 25-07-2026 |
| Type and Capacity of Extinguisher | : MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ50%4 062/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 06101 To 6200 And 6105A                                      |                  |
| Month of Manufacturing            | : Jul/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 6105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 6101                                                         | Pass   | 6102     | Pass   | 6103     | Pass   | 6104     | Pass   |
| 6105                                                         | Pass   | 6106     | Pass   | 6107     | Pass   | 6108     | Pass   |
| 6109                                                         | Pass   | 6110     | Pass   | 6111     | Pass   | 6112     | Pass   |
| 6113                                                         | Pass   | 6114     | Pass   | 6115     | Pass   | 6116     | Pass   |
| 6117                                                         | Pass   | 6118     | Pass   | 6119     | Pass   | 6120     | Pass   |
| 6121                                                         | Pass   | 6122     | Pass   | 6123     | Pass   | 6124     | Pass   |
| 6125                                                         | Pass   | 6126     | Pass   | 6127     | Pass   | 6128     | Pass   |
| 6129                                                         | Pass   | 6130     | Pass   | 6131     | Pass   | 6132     | Pass   |
| 6133                                                         | Pass   | 6134     | Pass   | 6135     | Pass   | 6136     | Pass   |
| 6137                                                         | Pass   | 6138     | Pass   | 6139     | Pass   | 6140     | Pass   |
| 6141                                                         | Pass   | 6142     | Pass   | 6143     | Pass   | 6144     | Pass   |
| 6145                                                         | Pass   | 6146     | Pass   | 6147     | Pass   | 6148     | Pass   |
| 6149                                                         | Pass   | 6150     | Pass   | 6151     | Pass   | 6152     | Pass   |
| 6153                                                         | Pass   | 6154     | Pass   | 6155     | Pass   | 6156     | Pass   |
| 6157                                                         | Pass   | 6158     | Pass   | 6159     | Pass   | 6160     | Pass   |
| 6161                                                         | Pass   | 6162     | Pass   | 6163     | Pass   | 6164     | Pass   |
| 6165                                                         | Pass   | 6166     | Pass   | 6167     | Pass   | 6168     | Pass   |
| 6169                                                         | Pass   | 6170     | Pass   | 6171     | Pass   | 6172     | Pass   |
| 6173                                                         | Pass   | 6174     | Pass   | 6175     | Pass   | 6176     | Pass   |
| 6177                                                         | Pass   | 6178     | Pass   | 6179     | Pass   | 6180     | Pass   |
| 6181                                                         | Pass   | 6182     | Pass   | 6183     | Pass   | 6184     | Pass   |
| 6185                                                         | Pass   | 6186     | Pass   | 6187     | Pass   | 6188     | Pass   |
| 6189                                                         | Pass   | 6190     | Pass   | 6191     | Pass   | 6192     | Pass   |
| 6193                                                         | Pass   | 6194     | Pass   | 6195     | Pass   | 6196     | Pass   |
| 6197                                                         | Pass   | 6198     | Pass   | 6199     | Pass   | 6200     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**