

HYDRO PRESSURE TEST

TC No.: HPT/MM6/SP/RQ/006/26	Model No.: MMSRQ-6	Date: 21-07-2026
Type and Capacity of Extinguisher	: MMSRQ-6-Kanex M Foam SP Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: MMSRQ6 006/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00101 To 120 And 105A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 105A and removed from the Lot/Batch							
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass	111	Pass	112	Pass
113	Pass	114	Pass	115	Pass	116	Pass
117	Pass	118	Pass	119	Pass	120	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory