

HYDRO PRESSURE TEST

TC No.: HPT/A9/M/RQ/011/26	Model No.: KFDMSRQ-9	Date: 02-08-2026
Type and Capacity of Extinguisher	: KFDMSRQ-9-Kanex D Type Metal SP Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFDMSRQ9 011/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00201 To 220 And 205A	
Month of Manufacturing	: Aug/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 205A and removed from the Lot/Batch							
201	Pass	202	Pass	203	Pass	204	Pass
205	Pass	206	Pass	207	Pass	208	Pass
209	Pass	210	Pass	211	Pass	212	Pass
213	Pass	214	Pass	215	Pass	216	Pass
217	Pass	218	Pass	219	Pass	220	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory