

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/A90/SS/HQ/008/26	Model No.: KFASSHQ-6-90%	Date: 04-08-2026
Type and Capacity of Extinguisher	: KFASSHQ-6-90%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFASSHQ90%6 008/26	
Batch Quantity	: 20 Nos.	
Serial Numbers	: 00141 To 160	
Month of Manufacturing	: Aug/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass	151	Pass	152	Pass
153	Pass	154	Pass	155	Pass	156	Pass
157	Pass	158	Pass	159	Pass	160	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory