

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/A3/K/HQ/011/26        | Model No.: KFKHQ-3                                            | Date: 07-07-2026 |
| Type and Capacity of Extinguisher | : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr. |                  |
| Batch Number                      | : KFKHQ3 011/26                                               |                  |
| Batch Quantity                    | : 11.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00101 To 110 And 105A                                       |                  |
| Month of Manufacturing            | : Jul/26                                                      |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 101                                                         | Pass   | 102      | Pass   | 103      | Pass   | 104      | Pass   |
| 105                                                         | Pass   | 106      | Pass   | 107      | Pass   | 108      | Pass   |
| 109                                                         | Pass   | 110      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**