

HELIUM LEAK DETECTION TEST

TC No.: HLD/A3/K/HQ/012/26

Model No.: KFKHQ-3

Date: 09-07-2026

Type and Capacity of Extinguisher : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.

Batch Number : KFKHQ3 012/26

Batch Quantity : 10 Nos.

Serial Numbers : 00111 To 120

Month of Manufacturing : Jul/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
111	Pass	112	Pass	113	Pass	114	Pass
115	Pass	116	Pass	117	Pass	118	Pass
119	Pass	120	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**