

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/100/26

Model No.: KFKHQ-6

Date: 05-07-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 100/26

Batch Quantity : 10 Nos.

Serial Numbers : 00991 To 1000

Month of Manufacturing : Jul/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
991	Pass	992	Pass	993	Pass	994	Pass
995	Pass	996	Pass	997	Pass	998	Pass
999	Pass	1000	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**