

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/100/26	Model No.: KFKHQ-6	Date: 03-07-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 100/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00991 To 1000 And 995A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 995A and removed from the Lot/Batch							
991	Pass	992	Pass	993	Pass	994	Pass
995	Pass	996	Pass	997	Pass	998	Pass
999	Pass	1000	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory