

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/102/26	Model No.: KFKHQ-6	Date: 03-07-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 102/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 01011 To 1020 And 1015A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1015A and removed from the Lot/Batch							
1011	Pass	1012	Pass	1013	Pass	1014	Pass
1015	Pass	1016	Pass	1017	Pass	1018	Pass
1019	Pass	1020	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory