

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/193/26      | Model No.: KFARQ-6-90%                                          | Date: 21-07-2026 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 193/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 19201 To 19300 And 19205A                                     |                  |
| Month of Manufacturing            | : Jul/26                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 19205A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 19201                                                         | Pass   | 19202    | Pass   | 19203    | Pass   | 19204    | Pass   |
| 19205                                                         | Pass   | 19206    | Pass   | 19207    | Pass   | 19208    | Pass   |
| 19209                                                         | Pass   | 19210    | Pass   | 19211    | Pass   | 19212    | Pass   |
| 19213                                                         | Pass   | 19214    | Pass   | 19215    | Pass   | 19216    | Pass   |
| 19217                                                         | Pass   | 19218    | Pass   | 19219    | Pass   | 19220    | Pass   |
| 19221                                                         | Pass   | 19222    | Pass   | 19223    | Pass   | 19224    | Pass   |
| 19225                                                         | Pass   | 19226    | Pass   | 19227    | Pass   | 19228    | Pass   |
| 19229                                                         | Pass   | 19230    | Pass   | 19231    | Pass   | 19232    | Pass   |
| 19233                                                         | Pass   | 19234    | Pass   | 19235    | Pass   | 19236    | Pass   |
| 19237                                                         | Pass   | 19238    | Pass   | 19239    | Pass   | 19240    | Pass   |
| 19241                                                         | Pass   | 19242    | Pass   | 19243    | Pass   | 19244    | Pass   |
| 19245                                                         | Pass   | 19246    | Pass   | 19247    | Pass   | 19248    | Pass   |
| 19249                                                         | Pass   | 19250    | Pass   | 19251    | Pass   | 19252    | Pass   |
| 19253                                                         | Pass   | 19254    | Pass   | 19255    | Pass   | 19256    | Pass   |
| 19257                                                         | Pass   | 19258    | Pass   | 19259    | Pass   | 19260    | Pass   |
| 19261                                                         | Pass   | 19262    | Pass   | 19263    | Pass   | 19264    | Pass   |
| 19265                                                         | Pass   | 19266    | Pass   | 19267    | Pass   | 19268    | Pass   |
| 19269                                                         | Pass   | 19270    | Pass   | 19271    | Pass   | 19272    | Pass   |
| 19273                                                         | Pass   | 19274    | Pass   | 19275    | Pass   | 19276    | Pass   |
| 19277                                                         | Pass   | 19278    | Pass   | 19279    | Pass   | 19280    | Pass   |
| 19281                                                         | Pass   | 19282    | Pass   | 19283    | Pass   | 19284    | Pass   |
| 19285                                                         | Pass   | 19286    | Pass   | 19287    | Pass   | 19288    | Pass   |
| 19289                                                         | Pass   | 19290    | Pass   | 19291    | Pass   | 19292    | Pass   |
| 19293                                                         | Pass   | 19294    | Pass   | 19295    | Pass   | 19296    | Pass   |
| 19297                                                         | Pass   | 19298    | Pass   | 19299    | Pass   | 19300    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**


 SIHOR  
 (GUJARAT)

**Authorized Signatory**