

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/213/26	Model No.: MARQ-6-40%	Date: 24-07-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 213/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21201 To 21300 And 21205A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21205A and removed from the Lot/Batch							
21201	Pass	21202	Pass	21203	Pass	21204	Pass
21205	Pass	21206	Pass	21207	Pass	21208	Pass
21209	Pass	21210	Pass	21211	Pass	21212	Pass
21213	Pass	21214	Pass	21215	Pass	21216	Pass
21217	Pass	21218	Pass	21219	Pass	21220	Pass
21221	Pass	21222	Pass	21223	Pass	21224	Pass
21225	Pass	21226	Pass	21227	Pass	21228	Pass
21229	Pass	21230	Pass	21231	Pass	21232	Pass
21233	Pass	21234	Pass	21235	Pass	21236	Pass
21237	Pass	21238	Pass	21239	Pass	21240	Pass
21241	Pass	21242	Pass	21243	Pass	21244	Pass
21245	Pass	21246	Pass	21247	Pass	21248	Pass
21249	Pass	21250	Pass	21251	Pass	21252	Pass
21253	Pass	21254	Pass	21255	Pass	21256	Pass
21257	Pass	21258	Pass	21259	Pass	21260	Pass
21261	Pass	21262	Pass	21263	Pass	21264	Pass
21265	Pass	21266	Pass	21267	Pass	21268	Pass
21269	Pass	21270	Pass	21271	Pass	21272	Pass
21273	Pass	21274	Pass	21275	Pass	21276	Pass
21277	Pass	21278	Pass	21279	Pass	21280	Pass
21281	Pass	21282	Pass	21283	Pass	21284	Pass
21285	Pass	21286	Pass	21287	Pass	21288	Pass
21289	Pass	21290	Pass	21291	Pass	21292	Pass
21293	Pass	21294	Pass	21295	Pass	21296	Pass
21297	Pass	21298	Pass	21299	Pass	21300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory